



Certificate / Certificat Zertifikat / 合格証

CRE 2101073 P0043 C001

exida hereby confirms that the:

**Krombach© TUFSEAT™ Ball Valves
KFO / KAO / KSO
11**/12**/51**/52**
Floating Ball Valves**

**Friedrich Krombach GmbH
Armaturenwerke - A Crane Co. Company
Kreuztal, Germany**

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:



Revision 1.0 July 16, 2021
Surveillance Audit Due
August 31, 2024



Evaluating Assessor

Certifying Assessor

CRE 2101073 P0043 C001

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Floating Ball Valve

| Application | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} |
|-------------------------------|----------------|----------------|----------------|----------------|
| Full Stroke, Clean Service | 0 | 0 | 0 | 414 |
| Tight Shutoff, Clean Service | 0 | 0 | 0 | 1154 |
| Open on Trip, Clean Service | 0 | 121 | 0 | 294 |
| Full Stroke, Severe Service | 0 | 0 | 0 | 737 |
| Tight Shutoff, Severe Service | 0 | 0 | 0 | 2213 |
| Open on Trip, Severe Service | 0 | 242 | 0 | 495 |

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: CRA 21/01-073-C R003 V0 R1

Safety Manual: CPE-KROMBACH TUFSEAT-Safety Manual V1R0



80 N Main St
Sellersville, PA 18960

Krombach©
TUFSEAT™ Ball Valves
KFO / KAO / KSO
11**/12**/51**/52**
Floating Ball Valves



Certificate / Certificat Zertifikat / 合格証

CRE 2101073 P0043 C002

exida hereby confirms that the:

**Krombach© TUFSEAT™ Ball Valves
KFO / KAO / KSO
71**/91****

Trunnion Ball Valves

**Friedrich Krombach GmbH
Armaturenwerke - A Crane Co. Company
Kreuztal, Germany**

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:



Revision 1.0 July 16, 2021
Surveillance Audit Due
August 31, 2024



Evaluating Assessor

Certifying Assessor

CRE 2101073 P0043 C002

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Systematic Capability:

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*

Trunnion Ball Valve

| Application | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} |
|-------------------------------|----------------|----------------|----------------|----------------|
| Full Stroke, Clean Service | 0 | 0 | 0 | 504 |
| Tight Shutoff, Clean Service | 0 | 0 | 0 | 1261 |
| Open on Trip, Clean Service | 0 | 121 | 0 | 383 |
| Full Stroke, Severe Service | 0 | 0 | 0 | 832 |
| Tight Shutoff, Severe Service | 0 | 0 | 0 | 2342 |
| Open on Trip, Severe Service | 0 | 242 | 0 | 590 |

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: CRA 21/01-073-C R003 V0 R1

Safety Manual: CPE-KROMBACH TUFSEAT-Safety Manual V1R0



80 N Main St
Sellersville, PA 18960

Krombach©
TUFSEAT™ Ball Valves
KFO / KAO / KSO
71**/91**
Trunnion Ball Valves